ADDENDUM No. 1 – (May 13, 2019)

Install Security Gate, Main Guard Post

ADDENDUM TO:

BID NUMBER:	ReBid #18-07
BID DUE DATE:	Thursday, May 16, 2019 not later than 10:00am
connection with the subjec	um is an integral part of the Bid file under consideration by you as a bidder in a matter identified above. For the purpose of clarification, the following ations and replacements noted below have been made to the Bid and have nich bears the above title.
Bids submitted shall conform addendums.	n to these additions and modifications noted herein and including all issued
Review attached no	ew map and questions/clarifications.
	oposal, of which this addendum becomes a part, this form must be completed office with the proposal.
Date:	
	Authorized Signature of Company Rep.
	Printed Name of Company Rep.
Company:	
Address:	
Telephone:	
Contact's Email:	

ADDENDUM ONE to ReBid #18-07

Install Security Gate, Main Guard Post Raymond James Stadium

The following information shall be incorporated into the Bid Documents:

1. Contact for electrical contractor used by TSA:

A & A Electric, Danny Perdomo, 813-267-7361

- 2. Since the Doorking 1601 gate is only available in the 14' length, Bidder should quote the gate arms with a maximum length of 20ft in length.
- 3. The control box for the north gate to be bid to be located on the opposite of the side shown on drawing. (see attached revised drawing) The entry operator shall have the ability to be removed. As noted in the specs, the final locations of the gates will be determined in the field between the owner and contractor prior to the beginning of construction or ordering of any materials.

END OF ADDENDUM



Power and fiber accessible from spare in cooling tower yard

1601-080 Doorking Barrier Gate
Operator and 16' 1602-520 Doorking
Barrier Gate Arm or approved equal
1601-080 Doorking Barrier Gate

1601-080 Doorking Barrier Gate
Operator and 16' 1601-520 Doorking
Barrier Gate Arm or approved equal